

**NON OFFICIAL CERTIFICATE
ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-20-003271B**

**Only the French PROCÈS-VERBAL is legally acceptable
*Seul le PROCÈS-VERBAL français est légalement acceptable.***

The French PROCES VERBAL is valid for 5 years starting on October 12th, 2020

Applicant	CGT ALKOR DRAKA 45 Rue Pasteur 60140 LIANCOURT France
Sample reference	2150
Brief description provided by the applicant	Flexible PVC foil with in the mass fire-retardant.
Mass per unit area determined by the laboratory	610 g/m ² ± 10%
Thickness measured by the laboratory	0,40 mm ± 10%
Color	White on one side and black on the other side.
End-use condition	Projection screen

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials
- **NF P 92-504 (1995)** - Reaction to fire tests - Flame persistence test and speed of the spread of flame

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512 : 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n° EFR-20-BE-003271B from October 12th, 2020.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on October 21st, 2020