

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-25-004087

Only the original French edition of this procès-verbal is authentic.  
*Seule l'édition originale en français du présent procès-verbal fait foi.*

The French PROCES VERBAL is valid for 5 years starting on October 03<sup>rd</sup>, 2025

<b>Applicant</b>	CGT ALKOR DRAKA 75 Rue Pasteur 60140 LIANCOURT France
<b>SIREN</b>	853039618
<b>Sample reference</b>	2150
<b>Brief description provided by the applicant</b>	100% in the mass fire-retardant PVC fabric.
<b>Mass per unit area determined by the laboratory</b>	627 g/m <sup>2</sup> ± 10%
<b>Thickness measured by the laboratory</b>	0,43 mm ± 10%
<b>Colour</b>	White on one side, black on the other
<b>End-use condition</b>	Screen

**Standard of tests:**

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials
- **NF P 92-504 (1995)** - Reaction to fire tests - Flame persistence test and speed of the spread of flame

**Classification obtained in the official Procès Verbal:**

M1

**Valid for any application for which the product is not subjected to the CE marking.**

**Durability of the classification (NFP 92-512: 1986):** Supposedly unlimited

*Taking into account the criteria resulting from the tests described in the test report n°EFR-25-004087-BE from October 03<sup>rd</sup>, 2025.*

*This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.433-3 of the Consumer Code and the Law of June 3<sup>rd</sup>, 1994.*

*Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5<sup>th</sup>, 1959.*

Saint-Aubin, on October 03<sup>rd</sup>, 2025